
# SIEMENS

# **Product data sheet**

## 3VL3725-1DC36-0AA0



CIRCUIT-BREAKER VL 250N STANDARD BREAKING CAPACITY ICU=55KA / 415 V AC 3 POLE, LINE PROTECTION OVERCURRENT RELEASE TM, LI IN=250A, RATED CURRENT IR=200-250A, OVERLOAD II=1200-2500A, SHORT-CIRCUIT WITHOUT AUXILIARY RELEASE WITHOUT AUXILIARY/ALARM SWITCH

Similar to image

General technical data:		
Number of poles		3
Design of the overcurrent release		ТМ
Acceptability for application		system protection
Electrical operating cycles as operating time / typical		10,000
Mechanical operating cycles as operating time / typical		20,000
Active power loss / maximum	W	80
Product component		
auxiliary switch		No
Voltage trigger		No
undervoltage release mechanism		No
<ul> <li>undervoltage release with leading contact</li> </ul>	_	No
Product function		
• of the thermal overload release		adjustable
ground-fault protection		No
<ul> <li>for zero conductors / short-circuit and overload protection</li> </ul>		No
overload protection		Yes
Operating cycles / maximum	1/s	120
Protection class IP		IP20

Protective function of the overcurrent release		U
Impulse voltage resistance / rated value	kV	8
Ambient temperature		
• during operating	°C	070
during storage	°C	-40 +80
Main aircuit.		
Main circuit:		200
Insulation voltage / for AC / rated value	V	800
Operating frequency		50
• 1 / rated value	Hz	50
• 2 / rated value	Hz	60
Reference code		
<ul> <li>according to DIN 40719 extended according to IEC 204-2 / according to IEC 750</li> </ul>		Q
according to DIN EN 61346-2		Q
Operating voltage / for main circuit		
• at 50 Hz / with AC		
• maximum	V	690
• at 60 Hz / with AC		
• maximum	V	690
Operating voltage / for main current circuit / for DC		
• maximum	V	500
Operating current		
• at 40 °C / rated value	А	250
• at 50 °C / rated value	А	250
• at 60 °C / rated value	А	232.5
• at 70 °C / rated value	А	215
Continuous current / rated value	А	250
Derating temperature / for the rated value of the continuous current	°C	50
Auxiliary circuit:		
Number of NC contacts / for auxiliary contacts		0
Number of NO contacts / for auxiliary contacts		0
Short-circuit:		
Adjustable response current		
of the current-dependent overload release	А	200 250
<ul> <li>of the non-delayed short-circuit release</li> </ul>	А	1,250 2,500
Breaking capacity limit short-circuit current (Icu) / at 415 V / rated value	kA	55

Installation/mounting/dimensions:							
Mounting type			fixed mounting				
Height		mm	185.5				
Width		mm	104.5				
Depth		mm	106.5				
Connections:							
Arrangement of electrical connectors / for main current circuit			front side				
Design of the electrical connection / for main current circuit			screw-type terminals				
Type of the connectable conductor cross-section							
<ul> <li>for main contacts</li> </ul>							
• solid			25 185 mm²				
• stranded			25 185 mm²				
<ul> <li>for auxiliary contacts</li> </ul>							
• solid			0.75 1.5 mm²				
<ul> <li>finely stranded / with conductor end processing</li> </ul>			0,75 1.0 mm²				
Certificates/approvals:							
General Product Approval		Declaration Conformity	of Test Certificates				
	TSE	EG-Konf.	Special Test Certificate				
Shipping Approval							
	ĴÅ DNV	GL					

 ABS
 Image: Confirmation of the result
 GL
 PRS
 RINA

 Shipping Approval
 other
 Environmental Confirmations

### Further information:

#### Information- and Downloadcenter (Catalogs, Brochures,...) http://www.siemens.com/lowvoltage/catalogs

# Industry Mall (Online ordering system)

https://eb.automation.siemens.com/mall/en/WW/Catalog/Product/3VL3725-1DC36-0AA0


Service&Support (Manuals, Certificates, Characteristics, FAQs,...) http://support.automation.siemens.com/WW/view/en/3VL3725-1DC36-0AA0/all


#### Image database (product images, 2D dimension drawings, 3D models, device circuit diagrams, ...) http://www.automation.siemens.com/bilddb/cax\_en.aspx?mlfb=3VL3725-1DC36-0AA0


### CAx-Online-Generator


http://www.siemens.com/cax

# Tender specifications Datanorm GAEB81 GAEB83 RTF TXT









last change:

Jun 16, 2014